



DG TYPE EXAMINATION CERTIFICATE

No.
DG-4045

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the description attached hereto.

Applicant	Integrated Gas Technologies ApS
Address	Gydevang 39-41, DK-3450 Allerød, Denmark
Type of Appliance	LPG jumbo adaptor
Trade Mark	IGT
Type/Model	C235is
Specified Standards	EN16129:2013

The attached (*description of type approval*) forms part of this certificate.
This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.

Date of issue	2017-10-04	Issued by	Danish Institute of Fire and Security Technology Notified Body No. 0845
---------------	------------	-----------	---

Signed

Name

Ken Olesen

Note:

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.



—XXXX

Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

This certificate is issued under the authority of the Danish Safety Technology Authority.



(Annex)
Description of Type Approval

Product Description

Trade Marks IGT
Type/Model C235is

Technical Data

Category: I_{3B/P}
Inlet pressure: 0.3 – 16 bar
Outlet pressure: Direct pressure
Temperature: -20°C - +50°C
Inlet connection: G 56
Outlet connection: H4 G1/4" LH, H6 G3/8" LH,
W21,8x1/14 LH

Comments: -

Type Approval Documentation

Test report : -

Drawings: No.: C235is-000-001, vers. 1 rev. A

Approval certificate No. : DG-4042 for model A235is regarding the G56 inlet connection.

Others: -

End of Certificate